

REQUIRED DISINFECTANT LEVELS FOR SPAS

DISINFECTANT TYPE	IF THE pH RANGE IS:	THEN THE DISINFECTANT LEVEL MUST BE BETWEEN:
CHLORINE*	7.2 – 7.49	2.5 – 10.0 PPM
	7.5 – 7.79	2.9 – 10.0
	7.8 – 8.0	3.3 – 10.0

CHLORINATED CYANURATE**	7.2 – 7.49	3.0 – 10.0
	7.5 – 7.79	3.5 – 10.0
	7.8 – 8.0	4.3 – 10.0

BROMINE	7.2 – 7.49	3.5 – 10.0
	7.5 – 7.79	4. – 10.0
	7.8 – 8.0	5.0 – 10.0

* EXAMPLES OF CHLORINE ARE GAS CHLORINE, LIQUID CHLORINE, HTH GRANULES (CALCIUM HYPOCHLORITE).

** EXAMPLES OF CHLORINATED CYANURATE ARE CHLORINE TABLETS, STICKS OR GRANULES CONTAINING “DICHLOR” OR “TRICHLOR” IN THEIR INGREDIENTS.